



1 **EU-TYPE EXAMINATION CERTIFICATE**

2 Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU

3 Certificate Number: **Sira 09ATEX2287X** Issue: **3**

4 Equipment: **IS-CP4A-**, IS-CP4B-** and BExCP5B-** Manual Call Points**

5 Applicant: **European Safety Systems**

6 Address: **Impress House
Mansell Road
Acton
London W3 7QH
UK**

7 This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 CSA Group Netherlands B.V., Notified Body Number 2813 in accordance with Articles 17 and 21 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 14.2.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule to this certificate, has been assured by compliance with the following documents:

EN IEC 60079-0:2018 EN 60079-11:2012 IEC 60079-26:2014 Ed 3 EN 60079-31:2014

10 If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to Specific Conditions of Use identified in the schedule to this certificate.

11 This EU-Type Examination Certificate relates only to the design and construction of the specified equipment. If applicable, further requirements of this Directive apply to the manufacture and supply of this equipment.

12 The marking of the equipment shall include the following:

IS-CP4A-**



II 1G2D
Ex ia IIC T6 Ga
Ex tb IIIC T60°C Db
(-40°C ≤ Ta ≤ +55°C)

IS-CP4B-**



II 1G
Ex ia IIC T4 Ga
(-40°C ≤ Ta ≤ +55°C)

BExCP5B-**



II 2D
Ex tb IIIC T70°C Db
(-40°C ≤ Ta ≤ +50°C)

Project Number 80019159

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.
Utrechtseweg 310,
6812 AR, Arnhem,
Netherlands

Signed: J A May
Title: Director of Operations



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 09ATEX2287X
Issue 3

13 DESCRIPTION OF EQUIPMENT

The equipment is a range of manual call points as described below:

Model	Protection concept	Description of enclosure	Enclosure contains	Mode of operation
IS-CP4A-BG	• or ,	Aluminium enclosure fitted with a glass window	A switch	Break glass
IS-CP4A-PB	• or ,	Aluminium enclosure fitted with a push button	A switch	Push button fitted with a spring-loaded cover that must be lifted before operating
IS-CP4A-PT	• or ,	Aluminium enclosure fitted with a push button	A switch	Push button fitted with a spring-loaded cover that must be lifted before operating, the push button can only be reset by a tool
IS-CP4B-BG	•	Aluminium enclosure fitted with a glass window	A switch and up to two resistors	Break glass
IS-CP4B-PB	•	Aluminium enclosure fitted with a push button	A switch and up to two resistors	Push button fitted with a spring-loaded cover that must be lifted before operating
IS-CP4B-PT	•	Aluminium enclosure fitted with a push button	A switch and up to two resistors	Push button fitted with a spring-loaded cover that must be lifted before operating, the push button can only be reset by a tool
BExCP5B-BG	,	Aluminium enclosure fitted with a glass window	A switch and up to two resistors	Break glass
BExCP5B-PB	,	Aluminium enclosure fitted with a push button	A switch and up to two resistors	Push button fitted with a spring-loaded cover that must be lifted before operating
BExCP5B-PT	,	Aluminium enclosure fitted with a push button	A switch and up to two resistors	Push button fitted with a spring-loaded cover that must be lifted before operating, the push button can only be reset by a tool

- Intrinsic Safety 'Ex ia' (Gases and Vapours) , Protection by Enclosure 'Ex t' (Dust)

In all cases, external connections are made via terminals mounted within the enclosure, the cables entering the enclosure via cable glands that are required to maintain the IP 66 protection of the enclosure. For 'Ex t' (dust) installations these cable glands are required to be suitably certified types.



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 09ATEX2287X
Issue 3

The following Intrinsic Safety Parameters/Ratings are applicable:

Model	Intrinsic Safety 'Ex ia' (Gases and Vapours)	Protection by Enclosure 'Ex t' (Dust)
IS-CP4A-BG	Ui = 30 V Ci = 0	AC Voltage 250 V Max., Current 5 A Max. DC Voltage 56 V Max., Current 1 A Max.
IS-CP4A-PB	Ii = 500 mA Li = 0	
IS-CP4A-PT	Pi = 1.1 W	
IS-CP4B-BG	Ui = 30 V Ci = 0	Not Applicable
IS-CP4B-PB	Ii = 500 mA Li = 0	
IS-CP4B-PT	Pi = 1.1 W	
BExCP5B-BG	Not Applicable	DC Voltage 56 V Max., Current 0.75 A Max. or
BExCP5B-PB		DC Voltage 28 V Max., Current 1.0 A Max. or
BExCP5B-PT		DC Voltage 15 V Max., Current 1.0 A Max. or DC Voltage 9 V Max., Current 1.0 A Max.

Variation 1 - This variation introduced the following change:

- i. Following appropriate assessment to demonstrate compliance with the latest technical knowledge, the documents previously listed, EN 60079-0:2006, EN 60079-0:2009 EN 60079-11:2007, EN 61241-1:2004 and EN 60079-26:2007 were replaced by EN 60079-0:2012, EN 60079-11:2012, EN 60079-31:2014 and IEC 60079-26:2014 Ed 3.0 the marking was amended accordingly.

Variation 2 - This variation introduced the following change:

- i. Following appropriate assessment to demonstrate compliance with the latest technical knowledge, the document previously listed, EN 60079-0:2012 was replaced by EN IEC 60079-0:2018.

14 DESCRIPTIVE DOCUMENTS

14.1 Drawings

Refer to Certificate Annexe.

14.2 Associated Sira Reports and Certificate History

Issue	Date	Report no.	Comment
0	16 March 2010	R18380A_00	The release of the prime certificate.
1	23 February 2015	R70006449E	The introduction of Variation 1.
2	15 October 2019	1700	<ul style="list-style-type: none"> • Transfer of certificate Sira 09ATEX2287X from Sira Certification Service to CSA Group Netherlands B.V.. • EC Type-Examination Certificate in accordance with 94/9/EC updated to EU Type-Examination Certificate in accordance with Directive 2014/34/EU. (In accordance with Article 41 of Directive 2014/34/EU, EC Type-Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Variations to such EC Type-Examination Certificates may continue to bear the original certificate number issued prior to 20 April 2016.)
3	05 December 2019	R80019159A	The introduction of Variation 2.

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.
Utrechtseweg 310,
6812 AR, Arnhem Netherlands



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 09ATEX2287X

Issue 3

- 15 **SPECIAL CONDITIONS FOR SAFE USE** (denoted by X after the certificate number)
- 15.1 Plain holes are provided for M20 cable glands or blanking elements. All of these shall be fitted with either a cable gland or blanking element that is suitable for the application and maintains the IP 66 protection provided by the enclosure. For 'Ex t' (dust) installations the cable glands or blanking elements shall also be certified by a notified body.
- 15.2 When located in Zone 0, the installation of the equipment shall ensure that the equipment enclosure is protected from impact.
- 16 **ESSENTIAL HEALTH AND SAFETY REQUIREMENTS OF ANNEX II (EHSRs)**
- The relevant EHSRs that are not addressed by the standards listed in this certificate have been identified and individually assessed in the reports listed in Section 14.2.

Certificate Annexe



Certificate Number: Sira 09ATEX2287X

Equipment: IS-CP4A-**, IS-CP4B-** and BExCP5B-**
Manual Call Points

Applicant: European Safety Systems

Issue 0

Drawing	Sheets	Rev.	Date (Sira stamp)	Title
D150-10-950-SC	1 of 1	B	10 Mar 10	IS-CP4BG/PB/PT Call Point Insulated Resistor Drawing
D150-00-501-CD-SC	1 of 1	B	10 Mar 10	IS-CP4A, IS-CP4B & BExCP5B Call Point Circuit Operation Diagram
D150-00-501-SC	1 of 1	C	10 Mar 10	IS-CP4A-BG, IS-CP4B & BExCP5B-BG Manual Call Point Assembly
D150-99-501-SC	1 of 1	D	10 Mar 10	IS-CP4A, IS-CP4B & BExCP5B Label Drawings

Issue 1

Drawing	Sheets	Rev.	Date (Sira stamp)	Title
D150-99-501-SC	1 of 1	E	28-Nov-14	IS-CP4A, IS-CP4B and BExCP5B Label Drawings

Issue 2 and 3. No new drawings were introduced

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.
Utrechtseweg 310,
6812 AR, Arnhem,
Netherlands